



DIFFUSER SCHEDULE

MARK	TYPE	FRAME	CFM	VEL.	S.P.	DAMPER
A	TITUS 6" x 6" TMDC-5-1	24" x 24" T- BAR ACROSS 1/8" EA. SIDE	190 CFM	500 FPM	.087	AG-95
B	TITUS 6" x 9" TMDC-5-1	"DO"	120 CFM	500 FPM	.087	AG-95
C	TITUS 12" x 12" TMDC-5-1	"DO"	500 CFM	500 FPM	.087	AG-95

HEATING & VENTILATING PLAN 1/8" = 1'-0"

24/94

RECEIVED FOR RECORD
 AT LUGP
 APR 19 1967
 RECORDED IN LORAIN
 COUNTY RECORDS
 Book Vol 24 Page 94
 LETA & BIRDELL
 Loran County Recorder

STATE OF OHIO
 WILLIAM S. UNGER
 2337
 REGISTERED
 ARCHITECT

GENERAL ELECTRIC FACTORY
 AVON INDUSTRIAL PARK AVON, OHIO

WILLIAM S. UNGER ARCHITECT
 470 N. RIDGE RD. E. LORAIN, OHIO
 TEL. 2-27-67. EM. 3-5-67. 2-N-67.

SHEET No. **6**